



Texas Commission on Environmental Quality

CERTIFICATE OF DELIVERY OF TIER I PUBLIC NOTICE TO CUSTOMERS:

Public Water System (PWS) name: SIESTA SHORES WCID _____
 PWS ID: 2530004 _____ Date of Violation 10/12/2023 _____
 Type of Violation: Low Water Pressure _____

MARY JAYNE
 WILLIAMS-BOHANNAN
 CLERK
 2023 OCT 12 P 2:15
 FILED
 ZAPATA COUNTY TEXAS

30 TAC 290.122(a) requires a PWS to notify customers of acute issues as soon as possible, but no later than 24 hours after the violation or situation is identified. The initial public notice shall be issued in **one or more** of the following manners that are reasonably calculated to reach persons served by the public water system within the required time period.

Please indicate how the PWS provided this public notice to customers, mark all that apply:

COMMUNITY WATER SYSTEM (perform one or more of the following):

- Furnish a copy of the Notice to radio and television stations serving the PWS service area
- Publish Notice in a local newspaper serving the PWS service area
- Direct delivery of Notice to customers
- Continuously post Notice in conspicuous places within affected PWS service area
- Electronic delivery or alert systems (e.g., reverse 911)

NONCOMMUNITY WATER SYSTEM (perform one or more of the following):

- Direct delivery of Notice to customers
- Continuously post Notice in conspicuous places within affected PWS service area
- Electronic delivery or alert systems (e.g., reverse 911)

In accordance with 30 TAC §290.122(g), all public water systems that are required to issue public notice to persons in accordance with 30 TAC §290.122, and that sell or otherwise provide drinking water to other public water systems (i.e., consecutive systems), shall provide public notice to the owner or operator of the consecutive systems.

This PWS provides water to consecutive systems and those systems have been provided public notice.

Notice to Consecutive Systems was delivered on: NA (date)
 by the following means: _____

Comments: Posted on Utility Web site and Social Media

“I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fines and imprisonment for knowing violations.”

NOTE: 30 TAC 290.122(f) requires the PWS to provide a copy of the Public Notice issued and a signed Certificate of

Delivery to the Executive Director within 10 days.

Date of Delivery to Customers: 10/12/2023 Phone: 956-795-4988 _____

Certified by: (print name): Marelda Garcia Title: Manager

Signature:  Date: 10/12/2023

Submit a copy of the Public Notice delivered to customers and a copy of this completed Certificate of Delivery to the TCEQ at:

E-mail: pwspn@tceq.texas.gov
Mail: TCEQ, Water Supply Division, MC-155
Attn: Public Notice
P.O. Box 13087
Austin, TX 78711-3087

MARY JAYNE
VILLARREAL-BONOLAN
CLERK
2023 OCT 12 P 2:45
FILED
ZAPATA COUNTY TEXAS
BY BJ

SIESTA SHORES WATER CONTROL AND IMPROVEMENT DISTRICT

5235 S. Siesta Lane
P.O. BOX 321
ZAPATA, TX 78076
1-956-765-4988

MARY JAYNE
VILLARREAL-BONDIAN
COUNTY CLERK

2023 OCT 12 P 2:45

FILED
ZAPATA COUNTY TEXAS

BY BJ DEPUTY

Boil Water Notice for Community Public Water Systems 10/12/2023

Due to Low Water Pressures in the Distribution System, the Texas Commission on Environmental Quality has required the **SIESTA SHORES WCID 2530004** public water system to notify all customers to boil their water prior to consumption (e.g., washing hands/face, brushing teeth, drinking, etc). Children, seniors, and persons with weakened immune systems are particularly vulnerable to harmful bacteria, and all customers should follow these directions).

To ensure destruction of all harmful bacteria and other microbes, water for drinking, cooking, and ice making should be boiled and cooled prior to use for drinking water or human consumption purposes. The water should be brought to a vigorous rolling boil and then boiled for two minutes.

In lieu of boiling, individuals may purchase bottled water or obtain water from some other suitable source for drinking water or human consumption purposes.

When it is no longer necessary to boil the water, the public water system officials will notify customers that the water is safe for drinking water or human consumption purposes.

Once the boil water notice is no longer in effect, the public water system will issue a notice to customers that rescinds the boil water notice in a manner similar to this notice.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

The lack of water pressure is due to the water plant being placed out of service due to the inability to provide a constant raw water supply to the plant. The Raw Water Pump is sitting in a shallow area due to the extremely low water level in Falcon Reservoir. The Raw Water Pump is being relocated by adding a new longer water supply pipe and new longer electrical cable. The opening of the interconnect from Zapata County Waterworks is not providing adequate pressures. We apologize for any inconvenience this action has caused. Staff are working diligently to correct problem. We will notify you as soon as the notice is rescinded.

If you have questions concerning this matter, you may contact Marelda Garcia, Manager, at 956-765-4988.